


การประชุมวิชาการทางวิศวกรรมไฟฟ้า ครั้งที่ ๓๙
The 39th Electrical Engineering



วันที่ ๒ - ๔ พฤศจิกายน ๒๕๕๙
โรงแรมเดอะ รีเจนท์ ซะอำบีช รีสอร์ท
จังหวัดเพชรบุรี



รวบรวมบทความในงานประชุม

Volume I

PW, PE, GN

EECON 39

สนับสนุนโดย



จัดการประชุมโดย ภาควิชาวิศวกรรมไฟฟ้า
คณะวิศวกรรมศาสตร์ จุฬาลงกรณ์มหาวิทยาลัย

CHULA ENGINEERING
Foundation toward Innovation

The Analysis and Control of Zero-Sequence Components in a Transformerless Back-To-Back (BTB) System Using Modular Multilevel Cascade Converters for Power Distribution Systems

Pracha Khamphakdi

Department of Electrical and Electronic Engineering, Faculty of Engineering,
Ubon Ratchathani University, Thailand 34190.
Email: pracha.k@ubu.ac.th

Abstract

This paper provides an intensive discussion on analysis and simulation of a back-to-back (BTB) system based on double-star chopper cells (MMCCs-DSCCs). It is installed between two 6.6-kV power distribution feeders. It is also referred to as the so-called "loop power flow controller." A three-phase 200-V, 10-kW, 50-Hz BTB transformerless system is simulated to verify its operating principles, modelling, and performance of zero-sequence current control using combination between a simple PI controller and a common-mode choke.

Keywords: Back-to-back (BTB) systems, distributed power generators, loop power flow controller, modular multilevel cascade converters (MMCCs), zero-sequence components.

1. Introduction

The power generation based on renewable energy is often called as distributed power generators (DGs) in contrast to centralized power generators because most of them are installed on power distribution systems [1]. Furthermore, in the future, an increasing part of the installed capacity will be connected to the DGs, which poses additional challenges to planning and safe operation of the systems [2]. In addition, flexible AC transmission system (FACTS) devices for control of power flow, voltage, and frequency are used to increase transmission capacity, reduce congestion, improve controllability and integrate more renewable energy into grids. For traditional two-level converters used in the above applications, step-up transformers and/or zigzag transformers are used to reach the medium and high voltage levels and to synthesize output voltage to multi-pulse waveforms [3]. However, transformers are bulky, lossy, high cost and present nonlinear/saturation problems that lead to difficulties in the system control.

Recently, attention has been paid to the "modular multilevel converter" (MMC) [4], [5] for high-voltage and high-power applications such as long-distance high-voltage direct-current (HVDC) transmission systems. According to the classification of modular multilevel cascade converters in [14], an MMCC using chopper cells is referred to as a double-star chopper cells (DSCC). Research scientist and engineers in power electronics and power systems have presented or published technical papers on DSCC-based power conversion systems with focus on control, modeling, analysis, design, and/or

operation [6], [7], [8], [9], [10]. The "HVDC-Plus" from Siemens [11], "HVDC-Light" from ABB [12], and "HVDC-Maxsine" from Alstom [13] are examples of the implementation of DSCC concept in applications of VSC-HVDC transmission. Some papers in the literature have focused on control, modeling, and performance of the DSCC-based BTB or HVDC systems during the voltage sags using different control strategies for mitigating and controlling the zero-sequence current components in the systems, especially in case of transformerless system [15].

The aim of this paper following [15] is to analyze and control the zero-sequence components in details when the BTB system is installed between two 6.6-kV power distribution feeders with many distributed power generators. It also referred to as the so-called "loop power flow controller." A simple modelling is used for simulation by the software package "PSCAD/EMTDC" to verify the validity and effectiveness of the zero-sequence current control techniques for the DSCC-based BTB system.




Fig. 1 A 6.6-kV power distribution system consisting of two radial feeders equipped with a DSCC-based BTB system [1].

2. Circuit Configuration and Equations

2.1 Circuit Configuration

Fig. 2(a) shows the circuit configuration for a transformerless DSCC-based BTB system used in experiments and simulations. Table 1 summarizes the circuit parameters of Fig. 2(a). Fig. 2(a) is a simplified model of Fig. 1, in which the following reasonable assumptions are made:

- the line-frequency transformer is modeled by an ideal voltage source presenting no background system inductance and leakage inductance;
- the impedances in feeder A and feeder B are neglected, while two ac-link inductors are used to connect the feeders and the BTB system;
- the currents flowing to the loads or flowing out from the distributed power generators are set to zero.

2.2 Circuit Equations

Fig. 2(a) shows the power circuit configuration of the DSCC-based BTB system with a per-leg chopper-cell count of 16 producing 17-level (33-level in line-to-line) pulse width modulation (PWM) waveforms [16]. The chopper-cell uses a dc capacitor and two IGBTs that form a bidirectional chopper as shown in Fig. 2(b). Here, v_{ju} is the low-voltage side voltage of each chopper-cell. In Fig. 2(a), a couple of identical DSCCs, "DSCC-A" and "DSCC-B" are connected back-to-back without any common dc-link capacitor. Each DSCC consists of 48 chopper cells depicted in Fig. 2(b), and three-center-tapped inductor in Fig. 2(c). In Fig. 2(a), i_{puA} and i_{nuA} are the positive and negative arm currents, i_{suA} is the supply current, and i_{zuA} is the circuit current along the u-phase leg of DSCC-A. Hence, the following equations exist among the four currents:

$$i_{zuA} = \frac{1}{2}(i_{puA} + i_{nuA}). \quad (1)$$

$$i_{puA} = -\left(\frac{i_{suA}}{2} + i_{zuA}\right), \quad (2)$$

$$i_{nuA} = \left(\frac{i_{suA}}{2} + i_{zuA}\right), \quad (3)$$




Fig. 2 Circuit configuration for the transformerless DSCC-based BTB system with a cascade of $n = 16$. (a) Main circuit. (b) Chopper cell. (c) Center-tapped inductor [15].

3. Modelling and Zero-Sequence Components

A zero-sequence current i_0 may flow when two load ends of feeder A and feeder B are connected by a transformerless BTB system, in which i_0 is defined as

$$i_0 = \sum_{x=u,v,w} i_{pxA} = \left(-\sum_{x=u,v,w} i_{pxA} + \sum_{x=u,v,w} i_{NxA}\right) = i_{Pdc} - i_{Ndc}. \quad (4)$$

Fig. 3 shows an equivalent circuit with a focus on zero-sequence components derived in [1]. Here, each arm is represented by a voltage source (e.g., v_{puA} or v_{nuA}), which is the sum of low-voltage-side voltages of the

corresponding chopper cells. It should be noted that i_0 circulates through feeder A and feeder B, and no zero-sequence current flows in the common ac mains because the 6.6-kV utility distribution systems in Japan are based on a three-phase ungrounding system. In addition, the background system inductance L_s does not affect i_0 because no zero-sequence current flows in L_s . Fig. 3(a) can be changed to Fig. 3(b), in which three wires at the ac sides are summarized to a single wire. Each of six legs in Fig. 3(b) produces the same amount of zero-sequence voltage. Fig. 3(b), therefore, is changed to Fig. 3(c), where v_0 is a zero-sequence voltage produced by each arm. The detail on how to derive Fig. 3(c) is given in [1].

Table 1 Circuit parameters of Fig. 2

Parameter	Symbol	Value
Rated power of the DSCCs	P	10 kW
Nominal line-to-line rms voltage	V_S	200 V
Nominal line frequency	f_s	50 Hz
Cascade count per leg	n	16
AC-link inductor	L_{ac}	2 mH (16%)*
Center-tapped inductor	L_Z	3 mH (24%)*
DC-link voltage reference	V_{dc}^*	400 V
DC-capacitor of each chopper cell	C	6.6 mF
DC-capacitor voltage reference	V_C^*	50 V (= 400 V/8)
Unit capacitance constant	H_C	40 ms at 50 V
Triangular carrier frequency	f_c	450 Hz
Equivalent carrier frequency	$16f_c$	7.2 kHz
Dead time (blanking time)	T_d	8 μ s
Common-mode choke at common dc link, 400 V, 25 A	L_{CM}	77 mH at 3.6 kHz (113 mH at 50 Hz)

* on a three-phase, 200-V, 10-kW, 50-Hz base.

Fig. 4 shows the block diagrams of power control and zero-sequence current control used in DSCC-A. The power control is achieved by the conventional decoupled current control and the detail is given in [13]. The zero-sequence current i_0 contains low-frequency components less than 1 Hz and switching-ripple components around several kilo-hertz. Ideally, i_0 contains no low-frequency components less than 1 Hz. However, they occur in the actual system due to the effect of passive-component tolerances, lead-wire resistances, tolerances in switching characteristics, and so on. This low-frequency component should be suppressed by applying the conventional PI (proportional-plus-integral) control, in which v_0^* is the common voltage reference which is determined by the feedback control of i_0 and its reference $i_0^* = 0$ as shown in Fig. 4. On the other hand, the switching-ripple components around several kilo-hertz should be suppressed by using the appropriately-designed common-mode choke L_{CM} connected to the common dc link [1].

4. Simulation and Analysis Results

Fig. 5 shows simulated waveforms of the zero-current components during normal voltage condition, where $p^* = 10$ kW and $q_A^* = q_B^* = 0$ kVA. Fig. 5(a) shows the zero-sequence voltage of DSCC-A, v_{0A} and that of DSCC-B, v_{0B} . Here, v_{0A} is not equal to v_{0B} . The zero-voltage component v_0 is 7.3 V in rms as shown in Fig. 5(b) while the voltage across common-mode choke v_{CM} is 10.2

V in rms as shown in Fig. 5(c). Fig. 5(d) show the three waveforms of zero-sequence current i_0 under different conditions such as: (1) No PI-control and No common-mode choke, (2) PI-control and No common-mode choke, and (3) PI-control and common mode choke. As can be seen in Fig. 5(d), i_0 consists of mainly dc component, low frequency components and high-switching ripple components. The dc and low-frequency components can be suppressed by using the PI-controller in which the rms value of i_0 is decreased from 1.86 A (No PI-control) to 0.5 A (with PI-control). However, the PI-control cannot suppress the high-frequency components.




Fig. 3 Equivalent circuits for zero-sequence components [1].

Fig. 6 shows frequency spectra of zero-sequence current (i_0) in Fig. 5(d). At the low-frequency band, the zero-sequence current are mainly composed by three dominant harmonic components: DC, baseband harmonics appear close to the fundamental frequency (50 Hz) in which the third-order harmonic is the most dominant as shown in Fig. 6(a), and side-band harmonics around switching ripple frequency at 3.6 kHz ($= 450 \text{ Hz} \times 16$) as shown in Fig. 6(b). It is usually hard to mitigate the low-frequency components and the high-frequency components by using only the control algorithm because the bandwidth of the PI-control method is lower than the high-switching frequency. Hence, the common-mode choke is used to suppress the high-frequency components. Finally, the combination of PI-controller and the

common-mode choke is applied to the system resulting into reducing of i_0 to be as small as 0.01 A in rms value. Here, the simulated results agree well with the theoretical analysis as mentioned earlier. Note that K_P and K_I of zero-sequence current controller in this experiment are set to 6.0 and 8.0, respectively.




Fig. 4 Block diagrams of power control and zero-sequence current control used in DSCC-A [15].




Fig. 5 Simulation waveforms of the zero-sequence components during normal voltage condition, where $p^* = 10 \text{ kW}$ and $q_A^* = q_B^* = 0 \text{ kVA}$. (a) Comparison between zero-sequence voltage of DSCC-A, v_{0A} and that of DSCC-B, v_{0B} . (b) Zero-sequence voltage $v_0 (= v_{0A})$. (c) Voltage across common-mode choke v_{CM} . (d) Zero-sequence current i_0 , under different conditions

5. Conclusion

This paper has described an application of a transformerless modular multilevel cascade converter based on a double-star chopper-cells (MMCC-DSCC). It is used to form a BTB (Back-To-Back) system installed between two 6.6-kV power distribution feeders working as the loop power flow controller. The simple modelling

of zero-sequence components have been done for analysis and control. Simulation results have confirmed the effectiveness of zero-sequence current suppression methods of PI control and common-mode choke. The zero-sequence current circulating between the two feeders can be suppressed as small as 0.01 A in rms at the rated dc-link current 25 A.




Fig. 6 Frequency spectra of zero-sequence current (i_0) in Fig. 5. (a) Low-frequency band. (b) High-frequency band.

References

- [1] P. Khamphakdi, K. Sekiguchi, M. Hagiwara, and H. Akagi, "A transformerless back-to-back (BTB) system using modular multilevel cascade converters for power distribution systems," *IEEE Trans. Power Electron.*, vol. 30, no. 4, pp. 1866–1875, Apr. 2015.
- [2] B. Gemmell, J. Dorn, D. Retzmann, and D. Soerangr, "Prospects of multilevel VSC technologies for power transmission," in *Transmission and Distribution Conference and Exposition, 2008. T&D. IEEE/PES, 2008*, pp. 1–16.
- [3] H. Abu-Rub, M. Malinowski, and K. Al-Haddad, *Power electronics for renewable energy systems, transportation and industrial applications*. John Wiley & Sons, 2014.
- [4] M. Perez, S. Bernet, J. Rodriguez, S. Kouro, and R. Lizana, "Circuit topologies, modeling, control schemes, and applications of modular multilevel converters," *IEEE Trans. Power Electron.*, vol. 30, no. 1, pp. 4–17, 2015.
- [5] A. Nami, J. Liang, F. Dijkhuizen, and G. Demetriades, "Modular multilevel converters for HVDC applications: Review on converter cells and functionalities," *IEEE Trans. Power Electron.*, vol. 30, no. 1, pp. 18–36, 2015.
- [6] S. Rohner, S. Bernet, M. Hiller, and R. Sommer, "Modulation, losses, and semiconductor requirements of modular multilevel converters," *Industrial Electronics, IEEE Transactions on*, vol. 57, no. 8, pp. 2633–2642, Aug. 2010.
- [7] S. Debnath, J. Qin, B. Bahrani, M. Saeedifard, and P. Barbosa, "Operation, control, and applications of the modular multilevel converter: A review," *IEEE Trans. Power Electron.*, vol. 30, no. 1, pp. 37–53, Jan. 2015.
- [8] J. Wang, R. Burgos, and D. Boroyevich, "A survey on the modular multilevel converters modeling, modulation and controls," in *Energy Conversion Congress and Exposition (ECCE), 2013 IEEE, 2013*, pp. 3984–3991.
- [9] M. Davies, M. Dommaschk, J. Dorn, J. Lang, D. Retzmann, and D. Soerangr, "HVDC PLUS basics and principle of operation," *Siemens Energy Sector, HVDC PLUS V3, Tech. Rep.*, 2008.
- [10] B. J. Claes Westerlind, Victor Lescale, "HVDC technology for large scale offshore wind connections," in *EWEA 2011, Brussels, Belgium: Europe's Premier Wind Energy Event, 2011*.
- [11] F. Hassan and C. Davidson, "HVDC-VSC: transmission technology of the future," *Alstom Grid Spring-Summer 2011 1, Tech. Rep.*, 2011.
- [12] H. Akagi, "Classification, terminology, and application of the modular multilevel cascade converter (MMCC)," *IEEE Trans. Power Electron.*, vol. 26, no. 11, pp. 3119–3130, Nov. 2011.
- [13] P. Khamphakdi, K. Sekiguchi, M. Hagiwara, and H. Akagi, "Zero-voltage ride-through capability of a transformerless back-to-back system using modular multilevel cascade converters for power distribution systems," *IEEE Trans. Power Electron.*, vol. 31, no. 4, pp. 2730–2714, Apr. 2016.
- [14] M. Hagiwara, R. Maeda, and H. Akagi, "Control and analysis of the modular multilevel cascade converter based on double-star chopper-cells (MMCC-DSCC)," *IEEE Trans. Power Electron.*, vol. 26, no. 6, pp. 1649–1658, Jun. 2011.
- [15] K. Sekiguchi, P. Khamphakdi, M. Hagiwara, and H. Akagi, "A grid-level high-power BTB (back-to-back) system using modular multilevel cascade converters without common DC-link capacitor," *IEEE Trans. Ind. Appl.*, vol. 50, no. 4, pp. 2648–2659, Jul/Aug. 2014.



Pracha Khamphakdi was born in Roi-Et, Thailand, in 1978. He received the Ph.D. degree in electrical engineering from the Tokyo Institute of Technology (TIT), Tokyo, Japan, in 2015. From 2006 to present, he is a Lecturer at the Department of Electrical and Electronic Engineering, Ubon-Ratchathani University, Ubon-Ratchathani, Thailand. His research interests include power converters for utility applications.

อิ
บทคัด
บ
ศาส
โดยสา
ต่อเฟส
สัญญา
ความพิ
MATL
นำเสนอ
คำสำคัญ
แปรค่า
Abstr
T
Variabl
A 11-
1,555
variabl
The sir
have cc
Keywo
Width l
1. บ
อิ
นำมาใ
แหล่งง
มอดอ:
ค้น โด
หลาย
อินเวอ
Multile
(Diode